



cfo-gmc@gujarat.gov.in



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOGMC/2025/00152210

Date: 29/12/2025

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOGMC/2025/00152210/R1

Building Occupancy/Category: Educational (non-residential)

To,

Indian Safety Solution
SAMARPAN PUBLIC SCHOOL NR KH-7 SAMARPAN CIRCLE SECTOR-28 GIDC GANDHINAGAR Gandhinagar MC 382028
Fire Region: Gandhinagar MC
Mobile No: 8866448339 Email ID: indiansafetysolution@gmail.com

We have received Application No.2025/00152306 dated 30/11/2025 for Fire Safety Certificate Renewal (FSCR) - New Building(FSCR)/Existing Building (FSCRe) for the building/premise SAMARPAN PUBLIC SCHOOL (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number: 286/1+286/2+288+294+295+931+932+933+935+939
3. Survey Number: 932 294
4. Village Name: GANDHINAGAR
5. Name of Block(s): 1

The building/premise was inspected on 29/12/2025 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 29/12/2025
2. Six monthly inspection was done on 29/12/2025

The Fire Safety Certificate is renewed for a period of two (2) years upto 29/12/2027 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated:29/12/2025 5:10:27 PM



Digitally Verified

Digitally verified by: Sajid Yakubhai Sheikh
Fire Safety Officer - General (FSO-G)
2021/000368
Reviewed by : CFO Gandhinagar MC
Date: 29/12/2025
Time: 06:02 PM



FSCA/O/CFOGMC/2025/00152210/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.